

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0587:104 Page 1 of 1

**CATEGORY:** Audible Signal Device

**LISTEE:** American Security Equipment Co., Division of Kobishi America Inc., 228 E. Star of India Lane, Carson CA 90746 Contact: Toby Tabata (310) 538-4670

**DESIGN:** Models BZ-52VT, BZ-VL4, BZ-54VT, BZ-VL4 horns and Model BZ-54SL fire alarm horns, suffix VT indicates terminal screw. Suffix VL4 indicated lead wire type connections. Suffix SL indicates an optional strobe light \*(Models RSD and SAD (CSFM Listing No. 7125-0587:111). \*Model without strobes are suitable for outdoor use with backbox and gasket.

\*Models SZ5424-153075, SZ5424T-153075, SZ5424-110 and SZ5424T-110 horn strobes.

Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 6, 12, 24, VDC

**INSTALLATION:** In accordance with the listee's printed installation instructions, wiring diagrams and applicable codes and ordinances. For indoor use only except for Models without strobe.

**MARKING:** Listee's name, model designation, electrical rating, audible output and UL label.

**APPROVAL:** Listed as an audible or audible/visual signaling devices suitable for fire alarm signal service as described under "DESIGN" and "APPLICATION.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliances must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

**NOTE:** \*Models SZ5424-153075, SZ5424T-153075, SZ5424-110 and SZ5424T-110 are also suitable for the hearing impaired applications.

\*Rev. 07-19-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 30, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager